



2023 Annual Report

Prepared by:



North Shore Water Utility
Nelson Ltd.

June 2024

Version: 1.0

© AquaDiversities Inc., 2024
ALL RIGHTS RESERVED. This report is copyrighted and contains proprietary and
privileged technical information that is the intellectual property of AquaDiversities Inc.
Any unauthorized reprint or use of this material is prohibited

Table of Contents

1.0 Introduction	3
2.0 Water System Overview	3
2.1 Source Description	3
2.2 Regulatory Requirements	3
2.3 Treatment System Description	4
2.4 Delivery and Distribution	4
3.0 Consumption Data	4
4.0 Operational Improvements and Capital Upgrades	4
4.1 Improvements to Date	4
4.2 Future Operational Improvements	5
5.0 Water Quality Monitoring Program	5
5.1 Parameters for Water Quality Monitoring	5
5.2 Real-time Monitoring	6
5.3 Microbiological Monitoring	6
5.4 Chemical Monitoring	7
5.5 Volume Monitoring at Reservoirs	7
6.0 Water Quality Concerns	7
7.0 Major Operational Events	7
8.0 Future Water Treatment	7
9.0 EOCP Classification and Certification	8
10.0 Summary	8

List of Tables

Table No. 1 - Water Quality Standards for Potable Water	5
Table No. 2 - Real-time Monitoring Results	5
Table No. 3 - Microbiological Monitoring Results	6

1.0 Introduction

As part of the conditions outlined in the Interior Health Authority Operating Permit for the North Shore Water Utility Nelson Ltd. (NSWU), this document will summarize and report the operations and maintenance of the utility in 2023 under the management of AquaDiversities Waterworks Inc.

Future treatment upgrades plans and customer feedback has also been included in this report. In an effort to provide transparency and inform the customers of the utility, this report will be posted on the NSWU website at <http://northshorewaterutility.com>.

Since September 2014 AquaDiversities Waterworks Inc. (Aqua) has owned and operated NSWU (a private water utility) under the *Water Utility Act*. The act regulates utilities to ensure the provision of safe and adequate water service at rates that are fair, reasonable and sufficient to operate their water systems sustainably.

2.0 Water System Overview

NSWU has been in operation since 1978 and services 143 residential connections along with five commercial connections.

2.1 Source Description

The surface water that supplies NSWU comes from two parallel sources consisting of high flow springs exiting the steep mountainside. They are known as Sutherland Creek and Collin Spring/Isaac Creek. Each of the sources has a wooden frame structure built over the spring to protect the intake infiltration galleries. These intakes supply the two 20,000 imperial gallon reservoirs (one located at each source). Flow to the reservoirs is controlled by an on-demand system of level switches and actuating valves. Access to each reservoir is contained within a building that houses the treatment components of the system and is locked to prevent unauthorized access. Both reservoirs are at the same elevation, providing gravity flow to the distribution system. In the high consumption summer months, both reservoirs are utilized to meet the demand of the consumers. For the majority of the year, the Collin Spring/Isaac Creek reservoir provides sufficient supply to meet the demand.

2.2 Regulatory Requirements

Interior Health Authority (IHA) is the regulatory agency for the NSWU. In British Columbia, water quality standards for potable water are regulated by *Drinking Water Protection Act* (2001), which provides the basic, minimum framework towards goals for drinking water treatment for pathogens in surface water supply systems. Specific water quality standards, monitoring schedules, applicability and recommended treatments are outlined in the *Drinking Water Protection Regulation* (2003). The objectives outlined in the *Guidelines for Canadian Drinking Water Quality* (Health Canada 2012) as

well as the *Drinking Water Treatment Objectives for Surface Water Supplies in British Columbia* (2012) are used to provide the treatment parameters for the treatment objectives implemented by the IHA. All results are reported to IHA to ensure compliance.

2.3 Treatment System Description

The system utilizes NSF approved chlorination disinfection to maintain the recommended operational range within the distribution system as outlined in the *Guidelines for Canadian Drinking Water Quality*. Each reservoir building houses a chemical dosing pump that doses 12% sodium hypochlorite (chlorine) proportionally to the flow of water being delivered to the reservoir. Aqua maintains the minimum level of chlorine required to ensure safe drinking water while preserving aesthetic quality.

2.4 Delivery and Distribution

The system provides potable water to approximately 2.5 km of distribution system main via gravity flow. The distribution system is comprised primarily of 6" diameter PVC, with some 2" and 4" diameter pipe. There are 11 fire hydrants and one standpipe that are utilized for system flushing. Each house has a curb stop valve connected to the main, which allows for isolation of the residence. In 2019 an extension of the NSWU was completed with an additional five new connections along a 6" main which included three new hydrants.

3.0 Consumption Data

As part of a pilot project, a totalizing non-intrusive (bolted to outside of pipe) flow meter was installed at Isaac Creek. Average daily consumption and average flow (m³/hour) was reported monthly since installation.

The following flow information was extrapolated for 2023:

- Average daily consumption from January 1st – December 31st = 188.72 m³/day
- Average daily flow = 7.8 m³/hour
- Total flow in 2022 = 68,779.76 m³

This is a decrease over 2022 consumption of: 9.45 m³/day, 0.45 m³/hour and overall total flow decrease of 3,452.59 m³.

4.0 Operational Improvements and Capital Upgrades

4.1 Improvements to Date

Since 2014 and throughout 2023, Aqua has worked diligently to ensure safe drinking water to the consumers of NSWU while making upgrades to the aging infrastructure and acquiring/documenting knowledge on the system.

Upgrades and improvements made to the NSWU in 2023 include:

- Conducting routine chlorine residual and turbidity monitoring; routine bi-monthly microbiological sampling and submitting a monthly report to the Environmental Health Officer;
- Maintaining/implementing a Water Conservation Program with established procedures for administering water restrictions, as well as water conservation tips for users;
- Maintaining the access road to the Isaac Creek and Sutherland Creek reservoirs;
- Compiling information on the collection, storage, usage, and distribution system of the utility. The comprehensive base map of the system is updated as more information becomes available;
- Routinely cleaning storage reservoirs;
- Hydrant maintenance, exercising and greasing;
- Replacing the service connection under the highway and upgrading to 6" C900 PVC in line with municipal standard;
- Distribution system flushing; and
- Exercising of all main control isolation valves.

4.2 Future Operational Improvements

Upgrading the Sutherland reservoir to have continuous monitoring similar to Issac reservoir.

5.0 Water Quality Monitoring Program

A Water Quality Monitoring Program provides established schedules for systematic, routine sampling to ensure that the parameters outlined in the *Guidelines for Canadian Drinking Water Quality* are maintained. The NSWU monitoring program has been developed with the approval of the EHO.

5.1 Parameters for Water Quality Monitoring

Parameters for water quality monitoring applicable to treatment currently being implemented at NSWU are summarized in **Table No. 1** below, with the exception of chemical parameters which can be found in the following link: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/sum_guide-res_recom/index-eng.php#t2.

Table No. 1 - Water Quality Standards for Potable Water

Parameter	Standard
Fecal Coliform Bacteria	No detectable fecal coliform bacteria per 100 ml
Escherichia Coli (E. Coli)	No detectable E. Coli per 100 ml
Total Coliform Bacteria	At least 90% of samples have no detectable total coliform bacteria per 100 ml and no sample has more than 10 total coliform bacteria per 100 ml.
Turbidity	Less than or equal to 1 Nephelometric Turbidity Unit (NTU)
Chlorine Residual	Greater than or equal to 0.2 mg/L at the end of the distribution system.

5.2 Real-time Monitoring

Real-time monitoring is data collected by the operators on an interval determined by the local EHO for turbidity and chlorine residual to ensure they are within drinking water quality standards. Samples are collected three times per week at one or both reservoirs, depending on operation, and at two locations at the ends of the distribution system. The system is also monitored remotely on a daily basis. Results are forwarded to the EHO in the Operator Log Sheets as part of the Monthly Report. Any sample results that fall outside of the standards are immediately addressed in accordance to the procedures outlined in the ERP.

Table No. 2 - Real-time Monitoring Results

Parameter	No. of Samples Taken	Range	Samples Outside of Standards
Raw Turbidity (Reservoir)	136	0.3 – 1.7 NTU	N/A
Chlorine Residual Distribution- 538 Johnstone Rd.	99	0.27 – 1.13mg/L	0

Chlorine Residual Distribution –Main Jet	97	0.19 – 1.12mg/L	0
Chlorine Residual Reservoir	137	0.3 – 1.04mg/L	0

5.3 Microbiological Monitoring

Microbiological monitoring occurs through bi-weekly sample collections at two locations in the distribution system. These samples are sent to a provincially accredited lab and tested for total and fecal coliforms. **Table No. 2** outlines the number of samples and results from this monitoring. Samples collected that exceed the parameters are immediately reported to the EHO and responded to in accordance to the procedures outlined in the ERP.

Table No. 3 - Microbiological Monitoring Results

Parameter	Number of Samples	Number of Exceedances
E. Coli	26	0
Total Coliform	26	0

5.4 Chemical Monitoring

A comprehensive chemical analysis is recommended every five years to ensure there are no exceedances to the Maximum Allowable Concentration (MAC) as defined in *Guidelines for Canadian Drinking Water Quality*. A routine comprehensive chemical analysis was performed at both intakes was conducted in July 2019 and included Trihalomethanes and Halo Acetic Acid testing. Full chemical analysis results can be found on the NSWU website at <http://northshorewaterutility.com>.

5.5 Volume Monitoring at Reservoirs

Operators monitor the volumes at the Isaac Creek reservoir closely in order to determine when the reservoir at Sutherland Creek will need to be brought online to supply the increased demand. Level 1 Water Conservation Measures (watering restrictions) were in effect from August 15th to September 30th in 2023. On May, 18th 2023 the Sutherland reservoir was brought online in anticipation of an increase in demand on the NSWU. It remained on-line until September 21, 2023.

6.0 Water Quality Concerns

Although the water source at NSWU is of pristine quality, seasonal turbidity issues remain a concern, particularly with high precipitation weather events and spring freshet. *The Drinking Water Treatment Objectives for Surface Water Supplies in BC (November 2012)* states the following:

“For non-filtered surface water to be acceptable as a drinking water source supply...turbidity levels of around 1 NTU but not exceeding 5.0 NTU for more than 2 days in a 12-month period should be demonstrated in the absence of filtration.”

The NSWU had a Water Quality Advisory (WQA) in place from March 21st to May 31st. The average turbidity throughout the duration of the WQA was 1.2 NTU. Had the turbidity levels exceed 5.0 NTU, a Boil Water Advisory would have been posted. The WQA can be attributed to an influx of natural organic matter due to heavy amounts of melting snow and heavy rainfall events, it should be noted that chlorine residuals were monitored and maintained daily throughout the WQA period.

In an effort to mitigate turbidity levels above 1 NTU, operators clean both intakes on regular intervals to remove sediment build-up. A flushing program to remove distribution system sedimentation was carried out in the spring of 2023.

7.0 Major Operational Events

- On June 16th the service connection under the highway by Main Jet and Nelco Marine on Hwy 3A was replaced and upgraded to 6" C900 PVC in line with municipal standard. Water was disrupted for a few residents along Hwy 3A for ~ 5 hours.

Communication methods for emergency repairs as well as routine maintenance included electronic alerts, customer email notification and sandwich boards in residential areas. These notifications will continue to be employed to ensure effective communication to all customers of the NSWU.

8.0 Future Water Treatment

In August 2016 a pilot treatment system project was installed at the Isaac Creek reservoir. This pilot system includes sand filtration, cartridge filtration, ultra-violet treatment, and a totalizing flow meter to the existing chlorination treatment. The pilot remains installed at the time of report writing as it continues to collect necessary information on water quality, water consumption rates, consumable and operating costs, and treatment effectiveness. This accrued knowledge will aid in developing a long-term plan for installing the water system to achieve treatment levels that meet the *Drinking Water Treatment Objectives for Surface Water Supplies in British Columbia*.

9.0 EOCP Classification and Certification

The Environmental Operators Certification Program (EOCP) classifications are done in accordance with the B.C. Guidelines that were established based on the classification templates developed in conjunction with the Association of Boards of Certification. It is used to determine the level of Operator Certification required to operate and maintain the treatment system and is reclassified every 5 years. NSWU was renewed as a Small Water System by the EOCP in September 2021 and as such requires a certified operator.

10.0 Summary

Throughout the 2023 operating season NSWU water quality results were within the *Maximum Acceptable Concentrations* (MAC) identified in the *Guidelines for Canadian Drinking Water Quality*. Operation and maintenance issues were resolved in a timely manner by AquaDiversities.

Overall, in 2023 the NSWU system was very stable, showing overall excellent water quality. The only concern being the elevated turbidity during spring freshet. Future plans for upgrades to the NSWU will be undertaken in 2024-2027, including potential plans to permanently install the water treatment system at the Isaac Creek reservoir. Future upgrades will be implemented to comply with regulatory requirements (IHA) in an effort to provide the customers of the NSWU a safe and sustainable potable water source and a satisfying relationship with the utility.

This report is for information purposes only. Aqua Diversities Inc. has provided accurate information to the best of their ability, and is not responsible for the inaccuracies that may occur from the collection of monitoring data.