

CERTIFICATE OF ANALYSIS

REPORTED TO	Aqua Diversities Inc. 621 Upper Park View Road Nelson, BC V1L 6H6	WORK ORDER	24H0242
ATTENTION	Nathan Ward	RECEIVED / TEMP REPORTED	2024-08-02 09:01 / 3.4°C 2024-08-09 09:19
PO NUMBER	NSWU SUTHERLAND RAW	COC NUMBER	No Number
PROJECT	NSWU - SUTHERLAND R		
PROJECT INFO			

Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks



You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too.

We've Got Chemistry



It's simple. We figure the more you enjoy working with our fun and engaged team members; the more likely you are to give us continued opportunities to support you.

Ahead of the Curve



Through research, regulation knowledge, and instrumentation, we are your analytical centre for the technical knowledge you need, BEFORE you need it, so you can stay up to date and in the know.

By engaging our services, you are agreeing to CARO Analytical Service's Standard Terms and Conditions outlined here: <https://www.caro.ca/terms-conditions>

If you have any questions or concerns, please contact me at smathew@caro.ca

Authorized By:

Sherine Mathew
Junior Account Manager

1-888-311-8846 | www.caro.ca

#110 4011 Viking Way Richmond, BC V6V 2K9 | #102 3677 Highway 97N Kelowna, BC V1X 5C3 | 17225 109 Avenue Edmonton, AB T5S 1H7 | #108 4475 Wayburne Drive Burnaby, BC V5G 4X4



TEST RESULTS

REPORTED TO PROJECT Aqua Diversities Inc.
NSWU - SUTHERLAND R

WORK ORDER REPORTED 24H0242
2024-08-09 09:19

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
---------	--------	-----------	----------	----------	-----------

EDWTK (24H0242-01) | Matrix: Water | Sampled: 2024-08-01 13:00

Anions

Chloride	< 0.10	AO ≤ 250	0.10 mg/L	2024-08-02	
Fluoride	< 0.10	MAC = 1.5	0.10 mg/L	2024-08-02	
Nitrate (as N)	< 0.010	MAC = 10	0.010 mg/L	2024-08-02	
Nitrite (as N)	< 0.010	MAC = 1	0.010 mg/L	2024-08-02	
Sulfate	1.4	AO ≤ 500	1.0 mg/L	2024-08-02	

Calculated Parameters

Hardness, Total (as CaCO3)	33.6	None Required	0.500 mg/L	N/A	
Solids, Total Dissolved	44.4	AO ≤ 500	1.00 mg/L	N/A	

General Parameters

Alkalinity, Total (as CaCO3)	43.8	N/A	1.0 mg/L	2024-08-03	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-08-03	
Alkalinity, Bicarbonate (as CaCO3)	43.8	N/A	1.0 mg/L	2024-08-03	
Alkalinity, Carbonate (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-08-03	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-08-03	
Conductivity (EC)	81.4	N/A	2.0 µS/cm	2024-08-03	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020 mg/L	2024-08-05	
pH	6.65	7.0-10.5	0.10 pH units	2024-08-03	HT2
Turbidity	0.62	OG < 1	0.10 NTU	2024-08-02	

Microbiological Parameters

Coliforms, Total	≥ 14	MAC = 0	1 CFU/100 mL	2024-08-02	
Background Colonies	>200	N/A	200 CFU/100 mL	2024-08-02	
E. coli	< 1	MAC = 0	1 CFU/100 mL	2024-08-02	

Total Metals

Aluminum, total	0.0263	OG < 0.1	0.0050 mg/L	2024-08-07	
Antimony, total	< 0.00020	MAC = 0.006	0.00020 mg/L	2024-08-07	
Arsenic, total	< 0.00050	MAC = 0.01	0.00050 mg/L	2024-08-07	
Barium, total	0.0617	MAC = 2	0.0050 mg/L	2024-08-07	
Boron, total	< 0.0500	MAC = 5	0.0500 mg/L	2024-08-07	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010 mg/L	2024-08-07	
Calcium, total	11.7	None Required	0.20 mg/L	2024-08-07	
Chromium, total	0.00127	MAC = 0.05	0.00050 mg/L	2024-08-07	
Copper, total	< 0.00040	MAC = 2	0.00040 mg/L	2024-08-07	
Iron, total	0.015	AO ≤ 0.3	0.010 mg/L	2024-08-07	
Lead, total	< 0.00020	MAC = 0.005	0.00020 mg/L	2024-08-07	
Magnesium, total	1.08	None Required	0.010 mg/L	2024-08-07	
Manganese, total	0.00051	MAC = 0.12	0.00020 mg/L	2024-08-07	
Potassium, total	0.79	N/A	0.10 mg/L	2024-08-07	
Selenium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2024-08-07	
Sodium, total	2.74	AO ≤ 200	0.10 mg/L	2024-08-07	
Strontium, total	0.170	MAC = 7	0.0010 mg/L	2024-08-07	



TEST RESULTS


REPORTED TO PROJECT Aqua Diversities Inc.
NSWU - SUTHERLAND R

WORK ORDER REPORTED 24H0242
2024-08-09 09:19

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
EDWTK (24H0242-01) Matrix: Water Sampled: 2024-08-01 13:00, Continued					
<i>Total Metals, Continued</i>					
Uranium, total	0.00536	MAC = 0.02	0.000020 mg/L	2024-08-07	
Zinc, total	< 0.0040	AO ≤ 5	0.0040 mg/L	2024-08-07	

Sample Qualifiers:

HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO PROJECT Aqua Diversities Inc.
NSWU - SUTHERLAND R


WORK ORDER REPORTED 24H0242
2024-08-09 09:19

Analysis Description	Method Ref.	Technique	Accredited	Location
Alkalinity in Water	SM 2320 B* (2021)	Titration with H2SO4	✓	Kelowna
Anions in Water	SM 4110 B (2020)	Ion Chromatography	✓	Kelowna
Coliforms, Total in Water	SM 9222* (2015)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Conductivity in Water	SM 2510 B (2021)	Conductivity Meter	✓	Kelowna
Cyanide, SAD in Water	ASTM D7511-12	Flow Injection with In-Line UV Digestion and Amperometry	✓	Kelowna
E. coli in Water	SM 9222* (2015)	Membrane Filtration / Chromocult Agar	✓	Kelowna
Hardness in Water	SM 2340 B* (2021)	Calculation: 2.497 [total Ca] + 4.118 [total Mg] (Est)	✓	N/A
pH in Water	SM 4500-H+ B (2021)	Electrometry	✓	Kelowna
Solids, Total Dissolved in Water	SM 1030 E (2021)	SM 1030 E		N/A
Total Metals in Water	EPA 200.2 / EPA 6020B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma-Mass Spectroscopy (ICP-MS)	✓	Richmond
Turbidity in Water	SM 2130 B (2020)	Nephelometry	✓	Kelowna

Note: An asterisk in the Method Reference indicates that the CARO method has been modified from the reference method

Glossary of Terms:

RL	Reporting Limit (default)
<	Less than the specified Reporting Limit (RL) - the actual RL may be higher than the default RL due to various factors
>=	Greater than or equal to the specified Result
>2	Greater than the specified Result
AO	Aesthetic Objective
CFU/100 mL	Colony Forming Units per 100 millilitres
MAC	Maximum Acceptable Concentration (health based)
mg/L	Milligrams per litre
NTU	Nephelometric Turbidity Units
OG	Operational Guideline (treated water)
pH units	pH < 7 = acidic, pH > 7 = basic
µS/cm	Microsiemens per centimetre
ASTM	ASTM International Test Methods
EPA	United States Environmental Protection Agency Test Methods
SM	Standard Methods for the Examination of Water and Wastewater, American Public Health Association



APPENDIX 1: SUPPORTING INFORMATION

REPORTED TO Aqua Diversities Inc.
PROJECT NSWU - SUTHERLAND R

WORK ORDER 24H0242
REPORTED 2024-08-09 09:19

General Comments:

The results in this report apply to the received samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Caro will dispose of all samples within 30 days of sample receipt, unless otherwise agreed. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted **red**. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do not take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager: smathew@caro.ca

Please note any regulatory guidelines applied to this report are added as a convenience to the client, at their request, to help provide some initial context to analytical results obtained. Although CARO makes every effort to ensure accuracy of the associated regulatory guideline(s) applied, the guidelines applied cannot be assumed to be correct due to a variety of factors and as such CARO Analytical Services assumes no liability or responsibility for the use of those guidelines to make any decisions. The original source of the regulation should be verified and a review of the guideline(s) should be validated as correct in order to make any decisions arising from the comparison of the analytical data obtained to the relevant regulatory guideline for one's particular circumstances. Further, CARO Analytical Services assumes no liability or responsibility for any loss attributed from the use of these guidelines in any way.